


System Performance and Health Report



PUSD Heights Elementary School
 40 Seeno Ave.
 Pittsburg, Pittsburg 94565

System Size (DC kW) 125.58
 Reporting Month March-17
 Performance Since February-12

System Performance ^{**} (2016)



Year of Operation	Budgeted Energy (kWh)	Actual Energy (kWh)	Production Vs. Budget
2012	171,770	205,293	119.5%
2013	176,732	210,431	119.1%
2014	175,848	103,255	58.7%
2015	174,969	191,167	109.3%
2016	174,094	185,759	106.7%
Jan-16	5,734	6,544	114.1%
Feb-16	7,802	12,657	162.2%
Mar-16	10,840	14,979	138.2%
Apr-16	17,388	19,866	114.3%
May-16	22,044	22,369	101.5%
Jun-16	22,857	23,974	104.9%
Jul-16	22,514	25,144	111.7%
Aug-16	20,671	22,717	109.9%
Sep-16	16,192	18,297	113.0%
Oct-16	12,879	9,225	71.6%
Nov-16	8,027	2,332	29.1%
Dec-16	7,145	7,655	107.1%
2017	13,468	16,393	121.7%
Jan-17	5,705	7,183	125.9%
Feb-17	7,763	9,210	118.6%
Total-Lifetime	1,060,976	1,098,057	103.5%

The system has produced at a higher percentage than modeled.

NOTE: Due to the cell modem issue addressed in CASE 11956, data from 10/22/16 - 11/21/16 was lost.

Please Let me know if you have any questions

Yvonne Grace
ygrace@recsolar.com

* System performance is Actual Energy/ Budgeted Energy. Budgeted Energy is based on a model and does not factor for real time weather conditions.

** The current Data Acquisition System (DAS) is not a reliable source for evaluating weather adjusted performance. If you would like more information on upgrading your DAS, please email us at the link below with the subject 'DAS UPGRADE'.

support@recsolar.com