


System Performance and Health Report



PUSD Highland Elementary School
 4141 Harbor St.
 Pittsburg, Pittsburg 94565

System Size (DC kW) 164.22
 Reporting Month March-17
 Performance Since February-12

System Performance ^{**} (2016)



Year of Operation	Budgeted Energy (kWh)	Actual Energy (kWh)	Production Vs. Budget
2012	224,640	271,803	121.0%
2013	231,109	267,008	115.5%
2014	229,953	226,896	98.7%
2015	228,803	253,267	110.7%
2016	227,659	246,132	108.1%
Jan-16	7,479	8,253	110.4%
Feb-16	10,194	16,336	160.3%
Mar-16	14,163	19,234	135.8%
Apr-16	22,749	25,426	111.8%
May-16	28,846	26,675	92.5%
Jun-16	29,904	24,829	83.0%
Jul-16	29,453	32,730	111.1%
Aug-16	27,042	30,049	111.1%
Sep-16	21,171	24,298	114.8%
Oct-16	16,839	15,752	93.5%
Nov-16	10,488	12,639	120.5%
Dec-16	9,331	9,911	106.2%
2017	17,584	22,203	126.3%
Jan-17	7,441	10,079	135.4%
Feb-17	10,143	12,124	119.5%
Total-Lifetime	1,387,407	1,533,441	110.5%

The system has produced at a higher percentage than modeled.

Please Let me know if you have any questions

Yvonne Grace
ygrace@recsolar.com

* System performance is Actual Energy/ Budgeted Energy. Budgeted Energy is based on a model and does not factor for real time weather conditions.

** The current Data Acquisition System (DAS) is not a reliable source for evaluating weather adjusted performance. If you would like more information on upgrading your DAS, please email us at the link below with the subject 'DAS UPGRADE'.

support@recsolar.com