


# System Performance Report



PUSD Los Medanos Elementary  
 610 Crowley Ave  
 Pittsburg, CA 94565

System Size (DC kW) 161.0  
 Reporting Month 6/30/2017  
 Performance Since: 6/10/2011

### System Performance\* (2017 to date)



	Year of Operation	Budgeted Energy (kWh)	Actual Energy (kWh)	Production Vs. Budget
	2011	124,470	146,270 ○	118%
	2012	241,192	287,975 ○	119%
	2013	239,986	302,386 ○	126%
	2014	238,786	280,063 ○	117%
	2015	237,592	279,397 ○	118%
	2016	236,405	270,898 ○	115%
	2017	114,440	133,484 ○	117%
2017	Jan-17	8,865	12,792 ●	144%
	Feb-17	11,449	13,845 ○	121%
	Mar-17	14,941	22,936 ●	154%
	Apr-17	22,977	23,589 ●	103%
	May-17	27,999	30,510 ●	109%
	Jun-17	28,209	29,812 ●	106%
	Total-Lifetime	1,432,872	1,700,473 ○	119%

The system is performing above the model.

Please Let me know if you have any questions,

Yvonne Grace  
[ygrace@recsolar.com](mailto:ygrace@recsolar.com)

\* System Performance is Actual Energy/ Budget Energy. Budgeted Energy is based on a model and does not factor for real time weather conditions