


System Performance and Health Report



PUSD Parkside Elementary
 985 W.17th St.
 Pittsburg, Pittsburg 94565

System Size (DC kW) 173.88
 Reporting Month March-17
 Performance Since February-12

System Performance ^{**} (2016)



Year of Operation	Budgeted Energy (kWh)	Actual Energy (kWh)	Production Vs. Budget
2012	237,490	275,464	116.0%
2013	244,342	286,542	117.3%
2014	243,120	265,421	109.2%
2015	241,905	269,449	111.4%
2016	240,695	249,371	103.6%
Jan-16	7,920	8,898	112.4%
Feb-16	10,772	17,068	158.5%
Mar-16	14,967	20,539	137.2%
Apr-16	24,063	27,080	112.5%
May-16	30,532	30,467	99.8%
Jun-16	31,639	32,693	103.3%
Jul-16	31,169	21,969	70.5%
Aug-16	28,601	25,806	90.2%
Sep-16	22,387	24,967	111.5%
Oct-16	17,751	16,235	91.5%
Nov-16	11,036	13,159	119.2%
Dec-16	9,860	10,490	106.4%
2017	18,598	22,870	123.0%
Jan-17	7,880	10,516	133.5%
Feb-17	10,718	12,354	115.3%
Total-Lifetime	1,466,846	1,618,488	110.3%

The system has produced at a higher percentage than modeled.

NOTE: The inverter was offline from 7/10/16 - 7/22/16 and again from 8/12/16 - 8/17/16 due to internal component failures. The failures were resolved under warranty, cases 11131 and 11460.

Please Let me know if you have any questions

Yvonne Grace
ygrace@recsolar.com

* System performance is Actual Energy/ Budgeted Energy. Budgeted Energy is based on a model and does not factor for real time weather conditions.

** The current Data Acquisition System (DAS) is not a reliable source for evaluating weather adjusted performance. If you would like more information on upgrading your DAS, please email us at the link below with the subject 'DAS UPGRADE'.

support@recsolar.com