


System Performance Report



PUSD Stoneman Elementary
 2929 Loveridge Rd
 Pittsburg, CA 94565

System Size (DC kW) 212.5
 Reporting Month 6/30/2017
 Performance Since: 5/17/2011

System Performance* (2017 to date)



Year of Operation	Budgeted Energy (kWh)	Actual Energy (kWh)	Production Vs. Budget	
2011	189,470	176,093	93%	
2012	297,962	346,127	116%	
2013	296,472	351,470	119%	
2014	294,990	336,797	114%	
2015	293,515	339,974	116%	
2016	292,048	322,289	110%	
2017	145,041	166,702	115%	
2017	Jan-17	9,528	13,188	138%
	Feb-17	12,971	15,688	121%
	Mar-17	18,081	27,127	150%
	Apr-17	29,199	30,092	103%
	May-17	36,952	40,753	110%
	Jun-17	38,310	39,854	104%
Total-Lifetime	1,809,499	2,039,452	113%	

The system is performing at above the model.

Please Let me know if you have any questions,

Yvonne Grace
ygrace@recsolar.com

* System Performance is Actual Energy/ Budget Energy. Budgeted Energy is based on a model and does not factor for real time weather conditions