


System Performance Report



PUSD Hillview Jr HS
 333 Yosemite Dr
 Pittsburg, CA 94565

System Size (DC kW) 276.9
 Reporting Month 6/30/2017
 Performance Since: 4/12/2011

System Performance* (2017 to date)



Year of Operation	Budgeted Energy (kWh)	Actual Energy (kWh)	Production Vs. Budget
2011	296,290	324,036 ●	109%
2012	387,693	423,899 ●	109%
2013	385,755	445,331 ○	115%
2014	383,826	422,795 ○	110%
2015	381,907	423,950 ○	111%
2016	379,997	414,347 ●	109%
2017	189,069	215,904 ○	114%
2017	Jan-17	12,347 ●	137%
	Feb-17	16,823 ○	121%
	Mar-17	23,533 ●	149%
	Apr-17	37,883 ●	103%
	May-17	48,325 ●	109%
	Jun-17	50,159 ●	104%
Total-Lifetime	2,404,538	2,670,262 ○	111%

The system is performing above the model.

Please Let me know if you have any questions,

Yvonne Grace
ygrace@recsolar.com

* System Performance is Actual Energy/ Budget Energy. Budgeted Energy is based on a model and does not factor for real time weather conditions