


System Performance Report



PUSD Rancho Medanos Jr HS
 2301 Range Rd
 Pittsburg, CA 94565

System Size (DC kW) 460.9
 Reporting Month 6/30/2017
 Performance Since: 5/20/2011

System Performance* (2017 to date)



	Year of Operation	Budgeted Energy (kWh)	Actual Energy (kWh)	Production Vs. Budget
	2011	430,990	403,548	94%
	2012	703,734	741,149	105%
	2013	700,216	716,412	102%
	2014	696,715	659,401	95%
	2015	693,231	672,766	97%
	2016	689,765	611,440	89%
	2017	356,292	351,454	99%
2017	Jan-17	27,073	25,558	94%
	Feb-17	33,129	32,313	98%
	Mar-17	60,348	56,850	94%
	Apr-17	67,819	63,983	94%
	May-17	79,726	86,868	109%
	Jun-17	88,197	85,882	97%
	Total-Lifetime	4,270,942	4,156,170	97%

The system is performing to model.

Please Let me know if you have any questions,

Yvonne Grace
ygrace@recsolar.com

* System Performance is Actual Energy/ Budget Energy. Budgeted Energy is based on a model and does not factor for real time weather conditions