


# System Performance and Health Report



PUSD Teacher Parking HS  
 250 School St  
 Pittsburg, Pittsburg 94565

System Size (DC kW) 344.54  
 Reporting Month March-17  
 Performance Since February-12

### System Performance <sup>\*\*</sup> (2016)



Year of Operation	Budgeted Energy (kWh)	Actual Energy (kWh)	Production Vs. Budget
2012	466,810	500,058	107.1%
2013	480,028	538,614	112.2%
2014	477,628	515,128	107.9%
2015	475,240	517,303	108.9%
2016	472,863	509,306	107.7%
Jan-16	15,320	15,639	102.1%
Feb-16	20,926	30,328	144.9%
Mar-16	29,522	38,862	131.6%
Apr-16	47,763	52,594	110.1%
May-16	61,210	61,063	99.8%
Jun-16	62,357	65,811	105.5%
Jul-16	62,661	68,601	109.5%
Aug-16	56,849	61,193	107.6%
Sep-16	43,970	46,541	105.8%
Oct-16	34,099	29,696	87.1%
Nov-16	19,819	22,060	111.3%
Dec-16	18,368	16,918	92.1%
2017	36,065	40,786	113.1%
Jan-17	15,243	17,956	117.8%
Feb-17	20,822	22,830	109.6%
<b>Total-Lifetime</b>	<b>2,881,496</b>	<b>3,130,501</b>	<b>108.6%</b>

The system has produced at a higher percentage than modeled.

NOTE: Due to the cell modem issue addressed in CASE 12876, data from 12/17/16 - 12/27/16 was lost.

Please Let me know if you have any questions

Yvonne Grace  
[ygrace@recsolar.com](mailto:ygrace@recsolar.com)

\* System performance is Actual Energy/ Budgeted Energy. Budgeted Energy is based on a model and does not factor for real time weather conditions.

\*\* The current Data Acquisition System (DAS) is not a reliable source for evaluating weather adjusted performance. If you would like more information on upgrading your DAS, please email us at the link below with the subject 'DAS UPGRADE'.

[support@recsolar.com](mailto:support@recsolar.com)