


System Performance and Health Report



PUSD Creative Art Building/Auditorium
 250 School St
 Pittsburg, Pittsburg 94565

System Size (DC kW) 64.40
 Reporting Month March-17
 Performance Since February-12

System Performance ^{**}
 (2016)



	Year of Operation	Budgeted Energy	Actual Energy	Production Vs.
	2012	84,470	100,711	119.2%
	2013	87,232	104,394	119.7%
	2014	86,795	98,844	113.9%
	2015	86,362	99,883	115.7%
	2016	85,930	96,892	112.8%
2016	Jan-16	3,136	3,031	96.6%
	Feb-16	4,175	5,947	142.4%
	Mar-16	6,694	6,349	94.8%
	Apr-16	8,508	9,973	117.2%
	May-16	10,566	11,530	109.1%
	Jun-16	10,958	12,557	114.6%
	Jul-16	11,517	13,169	114.3%
	Aug-16	9,919	11,665	117.6%
	Sep-16	8,018	8,934	111.4%
	Oct-16	5,940	5,836	98.3%
	Nov-16	3,627	4,463	123.1%
	Dec-16	2,872	3,440	119.8%
	2017	7,275	7,097	97.5%
	Jan-17	3,121	3,579	1
	Feb-17	4,155	3,518	1
	Total-Lifetime	430,788	500,724	116.2%

The has produced at a higher percentage than modeled.

Please Let me know if you have any questions

Yvonne Grace
ygrace@recsolar.com

* System performance is Actual Energy/ Budgeted Energy. Budgeted Energy is based on a model and does not factor for real time weather conditions.

** The current Data Acquisition System (DAS) is not a reliable source for evaluating weather adjusted performance. If you would like more information on upgrading your DAS, please email us at the link below with the subject 'DAS UPGRADE'.

support@recsolar.com