


System Performance Report



PUSD Boys & Girls Club
 1001 Stoneman Ave
 Pittsburg, CA 94565

System Size (DC kW) 58.0
 Reporting Month 6/30/2017
 Performance Since: 3/14/2011

System Performance* (2017 to date)



Year of Operation	Budgeted Energy (kWh)	Actual Energy (kWh)	Production Vs. Budget
2011	70,180	76,913 ●	110%
2012	81,163	87,535 ●	108%
2013	80,757	95,605 ○	118%
2014	80,353	90,666 ○	113%
2015	79,951	90,783 ○	114%
2016	79,552	88,173 ○	111%
2017	39,437	44,417 ○	113%
2017	Jan-17	2,600	3,454 ● 133%
	Feb-17	3,545	4,190 ○ 118%
	Mar-17	4,908	7,222 ● 147%
	Apr-17	7,914	8,016 ● 101%
	May-17	10,053	10,963 ● 109%
	Jun-17	10,416	10,572 ● 101%
Total-Lifetime	511,393	574,092 ○	112%

The system is performing above the model.

Please Let me know if you have any questions,

Yvonne Grace
ygrace@recsolar.com

* System Performance is Actual Energy/ Budget Energy. Budgeted Energy is based on a model and does not factor for real time weather conditions